



Product Service

Attestation of Conformity

No. N8A 099237 0012 Rev. 05

Holder of Certificate: **Jiangsu Eco Green Energy Co., Ltd**
No. 66 Shuangyun Road, Zixing Village, Xingdong Subdistrict,
Tongzhou District
226300 Nantong, Jiangsu
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704061830405-05

Date, 2021-09-06

(Zhulin Zhang)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 099237 0012 Rev. 05

Model(s):

EGE-xxxM-72, xxx=335 to 400, in step of 5
 EGE-xxxM-60, xxx=280 to 335, in step of 5
 EGE-xxxM-54, xxx=255 to 300, in step of 5
 EGE-xxxM-48, xxx=225 to 265, in step of 5
 EGE-xxxM-36, xxx=10 to 200, in step of 5
 EGE-xxxW-144M(M6), xxx=420 to 450, in step of 5
 EGE-xxxW-132M(M6), xxx=390 to 415, in step of 5
 EGE-xxxW-120M(M6), xxx=350 to 375, in step of 5
 EGE-xxxW-144M(G1), xxx=390 to 415, in step of 5
 EGE-xxxW-132M(G1), xxx=360 to 380, in step of 5
 EGE-xxxW-120M(G1), xxx=325 to 345, in step of 5
 EGE-xxxW-144M(M10), xxx=530 to 555, in step of 5
 EGE-xxxW-132M(M10), xxx=485 to 510, in step of 5
 EGE-xxxW-120M(M10), xxx=440 to 465, in step of 5
 EGE-xxxW-108M(M10), xxx=395 to 420, in step of 5
 EGE-xxxW-120M(M12), xxx=575 to 605, in step of 5
 EGE-xxxW-108M(M12), xxx=520 to 545, in step of 5
 EGE-xxxP-72, xxx=330-350, in step of 5
 EGE-xxxP-60, xxx=275-290, in step of 5
 EGE-xxxP-54, xxx=250-265, in step of 5
 EGE-xxxP-48, xxx=220-235, in step of 5
 EGE-xxxP-36, xxx=15-175, in step of 5
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute, No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China.

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.